

NOTICE OF ADDENDUM #2

THE CAMDEN COUNTY MUNICIPAL UTILITIES AUTHORITY CAMDEN, NEW JERSEY

BID CONTRACT #419 GLOUCESTER CITY AND COOPER RIVER PUMP STATIONS ELECTRICAL UPDGRADES

Johnson, Mirmiran & Thompson
1200 Lenox Drive, Suite 101
Trenton, New Jersey 08648

Notice is hereby given of the issuance of Addendum #2 for CONTRACT BID #419 GLOUCESTER CITY AND COOPER RIVER PUMP STATIONS ELECTRICAL UPDGRADES.

Prospective bidders and all concerned are hereby informed that the following changes are made as part of the contract documents and they are requested to amend all documents accordingly.

Prospective bidders are also reminded to acknowledge receipt of both Addendum No. 1 and Addendum No. 2, as per Paragraph 32 in the specifications, by submitting Exhibit Q, "Acknowledgement of Receipt of Addenda" with their bid.

I. Bidding and Contract Requirements, Specifications

A. Specifications

1. Section 26 31 10 – Electric Motors

A. Paragraph 2.3.A. has been revised to read as follows.

i. "Motors shall be furnished with a Weather-Protected Type I (WPI) enclosure."

B. Paragraph 2.11.D has been added and reads as follows.

i. "Motor mounting plates with machine registered fit to the existing motor base and a coupling insert to be used with the existing coupling shall be included.

B. Question Clarifications

The following are clarifications in response to project questions received. The responses are below each question in italics.

1. The specifications call out TEFC Design Motors. If the TEFC design is selected, the size of the VFD will need to be increased. If the chosen motors are the TEFC design, the

HP rating on the VFD will need to be increased. Please provide a response on how to proceed with the current rating of the new Motors.

The motor enclosure type has been changed from a totally enclosed fan cooled (TEFC) design to a weather-protected – type 1 (WPI) design, as per this addendum. Please refer to paragraph I.A. 1 of this addendum.

All provisions of the Bid documents and Addendum 1 not affected by this addendum shall remain in full force and effect.

A copy of this addendum will be sent in a manner authorized by law to all vendors who have received the bid specifications, are posted to the Camden County Purchasing Opportunities Web Portal, <https://procurements.camdencounty.com/> and are available in the Purchasing Department, Camden County Municipal Utilities Authority, Camden, NJ 08104.

Kevin McGahey, QPA
Director of Purchasing
Camden County Municipal Utilities Authority
May 8, 2026